



Product Service

Attestation of Conformity

No. N8A 118819 0002 Rev. 00

Holder of Certificate: **Amosolar Co., Ltd**
Room 605, Greenland Blue Ocean International Building
No. 210 Qianshan Road, Shushan District
230000 Hefei City, Anhui Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono -Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062263801-00

Date, 2022-12-05

(Zhulin Zhang)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 118819 0002 Rev. 00

Model(s):

ASxxxG12-132 (xxx=640-675 in steps of 5)
 ASxxxG12-120 (xxx=575-615 in steps of 5)
 ASxxxG12-110 (xxx=520-560 in steps of 5)
 ASxxxG12-100 (xxx=475-510 in steps of 5)
 ASxxxG12-80 (xxx=375-410 in steps of 5)
 ASxxxM10-108 (xxx=390-415 in steps of 5)
 ASxxxM10-120 (xxx=430-465 in steps of 5)
 ASxxxM10-144 (xxx=520-555 in steps of 5)
 ASxxxM6-120 (xxx=335-385 in steps of 5)
 ASxxxM6-144 (xxx=410-460 in steps of 5)
 xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. NO.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.